## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## FIRE ENGINEERING - DUILDING WATERIALS LISTING PRO

## LISTING SERVICE

**LISTING No.** 3774-0544:112 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Locknetics, 575 Birch Street, Forestville, CT 06010

Contact: \*Adam O'Day (860) 314-5248 Fax (860) 314-2452

DESIGN: Special locking arrangement, Models 6010, 6010NF, 6030, 6030NF, 6040 and 6040NF,

followed by DEL, may be followed by SEL, TEL, may be followed by ATS, DSM, MON, ATR, SCC, WRG, ATH, BOCA, MDE, MX500, RXL, FLL, FUL. Models 6010NF, 6030NF and 6040NF may be suffixed with MDG. The unit is designed keep the door secured in the closed position when the electromagnet is energized. Upon de-energization of the magnet, the door is free to swing open. Refer to listee's data sheet for additional detailed product description

and operational considerations.

RATING: 24 VDC

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes & ordinances,

NFPA 101 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic door locks for use with swinging type fire doors as a mean of

supplemental locking of the door in addition to the door's required latching mechanism when installed in accordance with the Uniform Building Code, Section 1004.5 Special Egress-Control Devices. Authority having jurisdiction shall be consulted prior to installation.

\*Rev. 05-16-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 30, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager